

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated:22.08.2025

No. -C/AZM/06

It is certified that an inspection team headed by **Satyendra Kumar (A.E)**, District Level Water Analysis Laboratory, Azamgarh (Name of officers with designation) from **UP Jal Nigam (Rural) Azamgarh** (Name of Department/office) Inspected the **Baba Bhawarnath Heaven School Devkhari, Azamgarh Uttar Pradesh** (Name & Address of the school) on **21.08.2025** (Date of inspection) and on the basis of water test report (Attached) Report no: **C/AZM/AUGUST/06** dated **22.08.2025** of District Level Water Analysis Laboratory, Azamgarh (PHED) lab certified that the **Baba Bhawarnath Heaven School Devkhari Azamgarh Uttar Pradesh** (Name of school) has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /state /U.T.Govt.

This certificate is valid till **01 Year** from date of issue. In case, if there is any change in Drinking Source /gone under maintenance before Expiry of certificate, then this certificate will be no more valid. So to avoid this problem School is advice to send Drinking Water Sample on Regular Interval to District Level Water Analysis Laboratory, Azamgarh.

Signature with Seal.....

Name Satyendra KumarDesignation A.E

Name & Address of the office/Department

**Uttar Pradesh Jal Nigam Rural, kolbaj Bahadur
(Pragati Nagar) Azamgarh 276001**

To

Director,
**Baba Bhawarnath Heaven School
Devkhari, Azamgarh Uttar Pradesh**
(Name & Address of the institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies.

WATER ANALYSIS REPORT



District Level Water Analysis Laboratory

U. P. Jal Nigam (Rural), Kolbaj Bahadur (Pragati Nagar),
Azamgarh- 276001

NABL T-8677

Report No.: C/AZM/06 Date: 22.08.2025 No. of Pages: 1

Office Name and Address: Baba Bhawarnath Heaven School Devkhari, Azamgarh (U.P)
Ref. Letter No. & Date: NA


Basic Details of Sample			
District	Azamgarh	Block	Palhani
Gram Panchayat	Devkhari	Village	Devkhari
Habitation	Main	Location	Baba Bhawarnath Heaven School Devkhari, Azamgarh
Water Source	R O (Water)	Sample Code	C/AZM/AUGUST/06
Quantity of Sample	1000 mL (Normal), 500 mL	Sampling date	21.08.2025
Sample Received Date	21.08.2025	Sample collected by	Sahab Chauhan (Manager)
Sampling Method Used	NA	Sample Depositor	Sahab Chauhan (Manager)
Analysis Start Date	21.08.2025	Analysis Completion Date	22.08.2025

S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	Taste		4	5	6
2	Odour	Agreeable	Agreeable/Not Agree.	Agreeable/Not Agree.	IS 3025 (Part 8):1984
3	Turbidity (NTU) **	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5):2018
4	pH **	1.12	1	5	APHA 24rd Ed. 2130- Turbidity Method B: 2023
5	Colour (Hazen units) **	7.69	6.5-8.5	6.5-8.5	APHA 24rd Ed. 4500 H+ Method B: 2023
6	Total Dissolved Solids, mg/l **	0.00	5	15	APHA 24rd Ed. 2120- B (Platinum Cobalt Visual Comparison): 2023
7	Chloride (as Cl), mg/l **	198	500	2000	APHA 24rd Ed. 2540- TDS Method C (Dried at 180 degree Celsius):2023
8	Total Alkalinity, (as CaCO3) mg/l **	82	250	1000	APHA 24rd Ed. 4500- CL Method B (Argentometric Method):2023
9	Total Hardness, (as CaCO3) mg/l **	102	200	600	APHA 24rd Ed. 2320- Alkaninity Method B (Titration method):2023
10	Calcium (as Ca), mg/l **	148	200	600	APHA 24rd Ed. 2340-Hardness Method C (EDTA Method):2023
11	Magnesium (as Mg), mg/l **	76	75	200	APHA 24rd Ed. 3500- Ca Method B (EDTA Method):2023
12	Sulphate (as SO4), mg/l **	88	30	100	APHA 24rd Ed. 3500- Mg Method B (By Calculation):2023
13	Nitrate (as NO3), mg/l **	17.89	200	400	APHA 24rd Ed. 4500- SO4 Method C (Gravimetric Method Ignition of Residue): 2023
14	Fluoride (as F), mg/l **	11.97	45	No relaxation	APHA 24rd Ed. 4500- NO3 Method E (Cadmium Reduction Method): 2023
15	Iron (as Fe), mg/l **	BDL(0.769)	1.00	1.50	APHA 24rd Ed. 4500-F Method C (Electrode Method):2023
16	Arsenic	BDL(0.002)	1.00	No relaxation	APHA 24rd Ed. 3111 -Fe Method B Direct A-Ac Flame AAS Method:2023
17	E.coli	BDL(0.001)	0.010	0.010	IS 3025 (Part 37): 1987 Silver diethyl Dithiocarbamate Method
18	Total Coliform	0.0	0.0	0.0	Membrane Filter Method
		0.0	0.0	0.0	Membrane Filter Method

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

- Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
 5. Parameters above Permissible Limit are written in bold.
 6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
 7. Sample is not Collected by Lab.
 8. ** Indicates Parameters are NABL Accredited.

ARVIND KUMAR VEDI
(Report Prepared by)


 SANDEEP KUMAR
 (Report Authorized by)

Laboratory Contact Details: Email: sandeepkumar181092@gmail.com Mobile No.: 8953458042

*****END OF THE ANALYSIS REPORT*****